



Original Certification: 06/17/2013  
Expiration Date: 06/17/2018  
Certification must be renewed annually.

Certification Number: **SWCC-11-04**

This Certificate is issued to:

**Kingspan Environmental Ltd.**  
180 Gilford Road, Portadown,  
Co. Armagh, BT63 5LF  
United Kingdom  
[www.kingspanenviro.com](http://www.kingspanenviro.com)

For the wind turbine model:

**KW6**

This Certificate represents that the above-identified Small Wind Turbine (SWT) is in conformance with the AWEA *Small Wind Turbine Performance and Safety Standard* (AWEA Standard 9.1 – 2009).

Changes to the Small Wind Turbine system design are to be approved by SWCC. If changes are made to the SWT without approval, this Certificate is not valid and is not in effect.

The wind turbine specifications relevant to this Certificate are provided on the following page.

*Shawn Martin*

Director of Technical Services



Please verify certification is active on the SRCC website.

© Solar Rating & Certification Corporation™

[www.solar-rating.org](http://www.solar-rating.org) ♦ ICC-SRCC ♦ 500 New Jersey Avenue, NW 6th Floor ♦ Washington, DC 20001 ♦ (888) 422-7233



Certification Number: SWCC-11-04

**Wind Turbine Specification:**

**Turbine parameters**

Manufacturer .....	Kingspan Environmental Ltd.
Model .....	KW6
Power Form.....	240 VAC, 1-phase, 60 Hz
Rotor Diameter .....	5.5 m
Rotor Swept Area .....	23.7 m <sup>2</sup>
Cut-In Wind Speed .....	2.5 m/s
Cut-Out Wind Speed .....	N/A
Maximum Power.....	6,135 W
Maximum Voltage.....	600 VAC, 3-phase from turbine
Maximum Currents .....	22 ADC into inverter 23 Arms from inverter

**Turbine Ratings**

AWEA Rated Annual Energy @ 5 m/s .....	8,950 kWh
AWEA Rated Sound Level .....	43.1 dB(A)
AWEA Rated Power .....	5.2 kW @ 11 m/s
Peak Power.....	6.1 kW @ 17 m/s

**Design and Duration**

Turbine design calculations comply with AWEA Standard 9.1 – 2009 for an IEC Class I SWT with an average wind speed ( $V_{ave}$ ) of 10 m/s and reference wind speed ( $V_{ref}$ ) of 50 m/s.

As a result of the particular wind distribution that occurred during the test period, it was not possible to demonstrate IEC Class I wind conditions. The turbine duration test complies with AWEA Standard 9.1 – 2009 for an IEC Class II SWT with an average wind speed ( $V_{ave}$ ) of 8.5 m/s and reference wind speed ( $V_{ref}$ ) of 42.5 m/s.

Please verify certification is active on the SRCC website.

© Solar Rating & Certification Corporation™

www.solar-rating.org ♦ ICC-SRCC ♦ 500 New Jersey Avenue, NW 6th Floor ♦ Washington, DC 20001 ♦ (888) 422-7233