



Original Certification: 12/19/2011
Expiration Date: 12/19/2018
Certification must be renewed annually.

Certification Number: **SWCC-10-20**

This Certificate is issued to:

Xzeres Wind Corporation
9025 SW Hillman Court, Suite 3126
Wilsonville, OR, 97070, USA
www.xzeres.com

For the wind turbine model:

Skystream 3.7

This Certificate represents that the above-identified Small Wind Turbine (SWT) is in conformance with the AWEA *Small Wind Turbine Performance and Safety Standard* (AWEA Standard 9.1 – 2009).

Changes to the Small Wind Turbine system design are to be approved by SWCC. If changes are made to the SWT without approval, this Certificate is not valid and is not in effect.

The wind turbine specifications relevant to this Certificate are provided on the following page.

Shawn Martin

Director of Technical Services



Please verify certification is active on the SRCC website.

© Solar Rating & Certification Corporation™

www.solar-rating.org ♦ ICC-SRCC ♦ 500 New Jersey Avenue, NW 6th Floor ♦ Washington, DC 20001 ♦ (888) 422-7233



Certification Number: SWCC-10-20

Wind Turbine Specification:

Turbine parameters

Manufacturer	Xzeres Wind Corporation
Model	Skystream 3.7
Power Form.....	240 VAC, 1-phase, 60 Hz
Rotor Diameter	3.7 m
Rotor Swept Area	10.9 m ²
Cut-In Wind Speed	3.0 m/s
Cut-Out Wind Speed	N/A
Maximum Power.....	2,629 W
Maximum Voltage.....	264 VAC from inverter
Maximum Current.....	10 A AC from inverter

Turbine Ratings

AWEA Rated Annual Energy @ 5 m/s.....	3,420 kWh
AWEA Rated Sound Level	41.2 dB(A)
AWEA Rated Power	2.1 kW @ 11 m/s
Peak Power.....	2.4 kW @ 14 m/s

Design and Duration

Turbine design and duration test comply with AWEA Standard 9.1 – 2009 for an IEC Class II SWT with an average wind speed (V_{ave}) of 8.5 m/s and reference wind speed (V_{ref}) of 42.5 m/s.

Please verify certification is active on the SRCC website.

© Solar Rating & Certification Corporation™

www.solar-rating.org ♦ ICC-SRCC ♦ 500 New Jersey Avenue, NW 6th Floor ♦ Washington, DC 20001 ♦ (888) 422-7233