

Solar Rating & Certification Corporation

Small Wind Certification Program

Manufacturer: **Lely Aircon**

Wind Turbine Model: **LA30** (480 VAC, 3-phase, 60 Hz)

Certification Number: **SWCC-16-02**



Rated Annual Energy

Estimated annual energy production assuming an annual average wind speed of 5 m/s (11.2 mph), a Rayleigh wind speed distribution, sea-level air density and 100% availability. Actual production will vary depending on site conditions.

48,800
kWh/year

Rated Sound Level

The sound level that will not be exceeded 95% of the time, assuming an annual average wind speed of 5 m/s (11.2 mph), a Rayleigh wind speed distribution, sea-level air density, 100% availability and an observer location 60 m (~ 200 ft) from the rotor center.

49.8
dB(A)

Rated Power

The wind turbine power output at 11 m/s (24.6 mph) at standard sea-level conditions.

27.2
kW

Certified to be in Conformance with:
AWEA Standard 9.1 – 2009

For SWCC Summary Report, Certificate and certification status visit:
www.smallwindcertification.org