



ICC-SWCC™ CERTIFICATION SWCC-10-20

Small Wind Turbine Certification Program

Issued: April 12, 2023
Expiration Date: April 12, 2024
Certification subject to renewal annually.

www.smallwindcertification.org (888) 422-7233 3060 Saturn St., Suite 100, Brea, CA 92821 USA

A Program of the ICC Evaluation Service (ICC-ES)

CERTIFICATION PROGRAM: This wind turbine has been evaluated and certified by the Small Wind Certification Council (ICC-SWCC™), an ISO/IEC 17065 accredited Certification Body, in accordance with the Small Wind Turbine Certification Program, as defined in *ICC-SWCC Rules for Wind Turbine Listing Reports* and the standards below.

PRODUCT: Small Wind Turbine (electricity-producing distributed wind turbine)
STANDARD: *AWEA Small Wind Turbine Performance & Safety Standard (AWEA 9.1-2009)*

LISTEE: **Wind Resource, LLC.**
4520 Main Street
Suite 1500
Kansas City, MO 64111
USA
www.skystreamturbines.com
816-731-0531

MODEL: **Skystream 3.7** (240 VAC, 1-phase, 60 Hz)

CONDITIONS:

This award of certification is subject to all terms and conditions of the current SWT Program Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

1. The turbine listed in this ICC-SWCC certification has been evaluated to the *AWEA 9.1-2009* standard and has been found to comply in accordance with the *ICC-SRCC Rules for Wind Turbine Listing Reports*. It is valid between the date of issuance and expiration and is subject to annual renewal. Certification validity should be confirmed on the ICC-SWCC website at www.smallwindcertification.org
2. Performance ratings are provided in accordance with the methodologies and conditions established by the *AWEA 9.1* standard. Actual results will vary based on the specific usage, installation and local environmental conditions.
3. The certified turbine must be installed in accordance with the manufacturer's published installation instruction and applicable codes. Certification does not address the turbine tower, foundation or the electrical safety.
4. Wind turbine manufactured by Wind Resource, LLC in Kansas City, Missouri, USA under a quality control program subject to periodic evaluation in accordance with the requirements of ICC-SWCC.



Please verify certification is active on the ICC-SWCC web directory.
©2023 Small Wind Certification Council (ICC-SWCC™)

ICC-SWCC™

CERTIFICATION SWCC-10-20



TURBINE PARAMETERS

Manufacturer Wind Resource, LLC
Model Skystream 3.7
Power Form 240 VAC, 1-phase, 60 Hz
Rotor Diameter 3.7 m
Rotor Swept Area 10.9 m²
Cut-In Wind Speed 3.0 m/s
Cut-Out Wind Speed N/A
Maximum Power 2,629 W
Maximum Current 10 AAC from inverter
Maximum Voltage 264 V AC from inverter

PERFORMANCE RATINGS

AWEA Rated Annual Energy 3,420 kWh @ 5 m/s
AWEA Rated Sound Level 41.2 dB(A)
AWEA Rated Power 2.1 kW @ 11 m/s
Peak Power 2.4 kW @ 14 m/s

DESIGN ASSESSMENT

Turbine design calculations comply with *AWEA Standard 9.1 – 2009* for an IEC Class II SWT with an average wind speed (V_{ave}) of 8.5 m/s and reference wind speed (V_{ref}) of 42.5 m/s.

DURATION TESTING AND IEC CLASSIFICATION

Turbine design and duration test comply with *AWEA Standard 9.1 – 2009* for an IEC Class II SWT with an average wind speed (V_{ave}) of 8.5 m/s and reference wind speed (V_{ref}) of 42.5 m/s.

Shawn Martin

Vice President of Technical Services, ICC-SWCC



Please verify certification is active on the ICC-SWCC web directory.
©2023 Small Wind Certification Council (ICC-SWCC™)